



King William County
Est. 1702

Board of Supervisors

Bobbie H. Tassinari
Director of Financial Services

William L. Hodges, First District
Travis J. Moskalski, Second District
Stephen K. Greenwood, Third District
David E. Hansen, Fourth District
Robert W. Ehrhart, Fifth District

KING WILLIAM COUNTY REGIONAL ANIMAL SHELTER GENERATOR DOCKING STATION ADDITION

IFB-2017-012—Addendum #1

ANSWERS TO QUESTIONS RECEIVED:

1. Page 1 Scope of Work: This indicates we are to install an automatic transfer switch, however the drawing indicates a manual transfer switch. Please clarify.
Revise the scope of work to delete the reference to the “automatic transfer switch” and replace with “manual transfer switch”.
2. Sheet E1, Note #1: What is the cable assembly length that would be required ?
The cable assembly shall be 20ft.
3. Note #2: Please verify the required catalogue # for the item. Can we provide an or equal product?
Yes, an “or equal” product can be submitted for review.